

Dated: 02-11-2018



Bid Details		
Bid End Date/Time	22-11-2018 11:00:00	
Bid Validity	90 (Days)	
Ministry/State Name	Haryana	
Department Name	Agriculture Department Haryana	
Organization Name	N/a	
Office Name	Budget	
Total Quantity	1	
Item Category	Online UPS	
Average Turn Over of Last 3 Years	20 Lakh (s)	
Experience with Gov. Required	10 Year (s)	
MSE Exemption For Years Of Experience And Turnover	Yes	

## Online UPS (1)

## **Technical Specifications**

### \* As per GeM Category Specification

Specification	Specification Name	Values	Allowed Values
GENERIC	Rating in KVA (KVA)	10.0 KVA	10.0 KVA
	Technology	IGBT-PWM with inbuilt isolation transformer	IGBT-PWM with inbuilt isolation transformer
	Input Power	single phase 160V - 260V sinewave,50Hz	single phase 160V - 260V sinewave,50Hz
	Output power	Single phase 230V +/-1% sinewave 50 Hz	Single phase 230V +/-1% sinewave 50 Hz
	Backup time (Minutes)	120	120
	Minimum VAH (VAH)	32000	32000
	Warranty for UPS (Years)	2	2
	Movable trolly for Batteries	Without trollery but with rack	Without trollery but with rack

	Warranty for battery	2	2
	Degree of Protection	IP21	IP21
	Cabling 5 meters for input and out put	Without	Without
	Paralleling kit for synchronising	Without	Without
	Installation and Commissioning	Yes	*
CONSTRUCTIONAL	Minimum thickness of M.S.Sheet Enclosure duly painted (mm)	1.2	*
	Type of Battery	SMF-VRLA conforming to JISC:8702(Pt.I,II&III)	*
FUNCTIONAL	Maximum overshoot and Under shoot of output rated voltage	4	*
	Voltage Regulation from no load to full load (%)		*
	20% Overload limit for minimum 10 minutes	Yes	*
	Overall Efficiency (%)	>/=90%	*
	Total Harmonic Distortion(THD) (%)	Maximum 3%	*
	50% Overload limit for minimum 1 minutes	Yes	*
PROTECTION	Protection for under voltage at battery terminal at 10.5V per 12 V battery.	Yes	*
	Protection of Over voltage, Short Circuit & over load at UPS output terminal	Yes	*
METERING AND INDICATIONS	Digital Metering in UPS for AC Input Voltage,Output AC Volt age,Current,Frequency, Battery Voltage and Current	Yes	*
	Indicators for mains presence,Battery charging and discharging,Output Over Load, Low Battery Voltage	Yes	*
REPORTS AND CERTIFICATION	Damp Heat : in accordance with	Yes	*

IS:9000(part 5/sec.2)1981 at Temperature of 40 degree C,two cycles of (12+12) hours each 2007)		
Dry Heat Test: in accordance with IS:9000 (part 3/sec.5)1977 (reaffirmed 2007) at 5 degree C for 16 hrs	Yes 5	*
Cold Test: in accordance with IS:9000 (Part 2/Sec.4)1977 (Reaffirmed 2007) at -10 degree C for 4 hrs.	Yes	*
Availability of the Type Test Report from Central Govt. /NABL/ILAC Accredited lab covering all technical requirements		*
Type Test Certificate No.	-	*
Type Test Certificate date	-	*
Name of Lab	-	*
Address of Lab	-	*
As per Meity (Government of India) guidelines UPS shall have valid BIS CRS certifications as applicable	Yes	*

<sup>\*</sup> Bold specifications are the golden parameters.

## **Consignees and Quantity**

S.No.	Consignee	Address	Quantity	Delivery Days
1	1 -	134116,udhyan bhawan sec 21 panchkula	1	15

#### **EMD Detail**

Required	No
----------	----

#### ePBG Detail

Required	No

#### **Splitting**

Bid splitting not applied.

# **Buyer Specific Additional Terms and Conditions**

1. Scope of supply (Bid price to include all cost components): Supply Installation Testing and Commissioning of Goods

This Bid is also governed by the General Terms and Conditions

---Thank You---