

### Bid Document

Bid Details	
Bid End Date/Time	14-02-2019 15:00:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	70 (Days)
Ministry/State Name	Ministry Of Petroleum And Natural Gas
Department Name	Indian Oil Corporation Limited
Organisation Name	locl- Panipat Refinery
Office Name	locl- Panipat Refinery
Total Quantity	300
Item Category	miniature circuit breakers , miniature circuit breakers , miniature circuit breakers
MSE Exemption For Years Of Experience And Turnover	No

### Miniature Circuit Breakers ( 100 )

#### Technical Specifications

[\\* As per GeM Category Specification](#)

Specification	Specification Name	Values	Allowed Values
GENERIC	Governing Indian Standard specification IS/IEC 60898-1:2002	Yes	*
	<b>Rated Current (Ampere)</b>	63 A	63 A
	<b>Instantaneous Tripping Range</b>	C	C
	<b>Rated Voltage (Volt)</b>	415 VOLT	415 VOLT
	<b>No of poles/Protected poles(PP)</b>	4 pole with 3PP	4 pole with 3PP
	ISI marking	Yes	*
	CM/L No:	-	*
	CM/L Validity up to	31/12/2018	*

CONSTRUCTIONAL	Steel sheet enclosure for MCB of 1.2 mm thickness duly pretreated stove enamelled/powder coated	Without	*
	Rated Short circuit capacity (Ampere)	10000 A	*
CERTIFICATIONS	Availability of Type test report from Central government/NABL/ILAC accredited laboratory to prove conformity to the specification for each rating.	yes	*
	Test Report number	-	*
	Date of issue of Test Report by Laboratory	-	*
	Test Report to be furnished to the buyer on demand	Yes	*

\* Bold specifications are the golden parameters.

#### Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Premsagar Sahu	132140,INDIANOIL CORPORATION LTD. PANIPAT REFINERY , PO. BOHALI , PANIPAT	100	30

#### Miniature Circuit Breakers ( 100 )

##### Technical Specifications

\* [As per GeM Category Specification](#)

Specification	Specification Name	Values	Allowed Values
GENERIC	Governing Indian Standard specification IS/IEC 60898-1:2002	Yes	*
	<b>Rated Current (Ampere)</b>	4.0	4.0
	<b>Instantaneous Tripping Range</b>	C	C
	<b>Rated Voltage (Volt)</b>	240 VOLT	240 VOLT
	<b>No of</b>	2 pole with 1PP	2 pole with 1PP

	<b>poles/Protected poles(PP)</b>		
	ISI marking	Yes	*
	CM/L No:	-	*
	CM/L Validity up to	31/1/2019	*
CONSTRUCTIONAL	Steel sheet enclosure for MCB of 1.2 mm thickness duly pretreated stove enamelled/powder coated	Without	*
	Rated Short circuit capacity (Ampere)	10000 A	*
CERTIFICATIONS	Availability of Type test report from Central government/NABL/ILAC accredited laboratory to prove conformity to the specification for each rating.	yes	*
	Test Report number	-	*
	Date of issue of Test Report by Laboratory	-	*
	Test Report to be furnished to the buyer on demand	Yes	*

\* Bold specifications are the golden parameters.

#### Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Premsagar Sahu	132140,INDIANOIL CORPORATION LTD. PANIPAT REFINERY , PO. BOHALI , PANIPAT	100	30

#### Miniature Circuit Breakers ( 100 )

##### Technical Specifications

[\\* As per GeM Category Specification](#)

Specification	Specification Name	Values	Allowed Values
GENERIC	Governing Indian Standard specification IS/IEC 60898-1:2002	Yes	*
	<b>Rated Current</b>	40 A	40 A

	<b>(Ampere)</b>		
	<b>Instantaneous Tripping Range</b>	C	C
	<b>Rated Voltage (Volt)</b>	415 VOLT	415 VOLT
	<b>No of poles/Protected poles(PP)</b>	4 pole with 3PP	4 pole with 3PP
	ISI marking	Yes	*
	CM/L No:	-	*
	CM/L Validity up to	31/12/19	*
CONSTRUCTIONAL	Steel sheet enclosure for MCB of 1.2 mm thickness duly pretreated stove enamelled/powder coated	Without	*
	Rated Short circuit capacity (Ampere)	10000 A	*
CERTIFICATIONS	Availability of Type test report from Central government/NABL/ILAC accredited laboratory to prove conformity to the specification for each rating.	yes	*
	Test Report number	-	*
	Date of issue of Test Report by Laboratory	-	*
	Test Report to be furnished to the buyer on demand	Yes	*

\* Bold specifications are the golden parameters.

#### Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Premsagar Sahu	132140,INDIANOIL CORPORATION LTD. PANIPAT REFINERY , PO. BOHALI , PANIPAT	100	30

#### EMD Detail

Required	No
----------	----

#### ePBG Detail

--	--

Required

No

**Splitting**

Bid splitting not applied.

**Buyer Specific Additional Terms and Conditions**

1. **Scope of supply (Bid price to include all cost components) :** Only supply of Goods

[This Bid is also governed by the General Terms and Conditions](#)

**---Thank You---**