

Bid Document

Bid Details	
Bid End Date/Time	19-11-2018 11:00:00
Bid Validity	90 (Days)
Ministry/State Name	Ministry Of Information And Broadcasting
Department Name	Na
Organization Name	Prasar Bharati Broadcasting Corporation Of India
Office Name	Engineering
Total Quantity	28
Item Category	lead acid battery
Experience with Gov. Required	1 Year (s)
MSE Exemption For Years Of Experience And Turnover	Yes

Lead Acid Battery (28)

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Allowed Values
GENERIC	Types of Lead Acid of Battery	Small sized Valve Regulated Lead -Acid Batteries (SMF) conforming to JISC: 8702/1998 (Part 1,2 & 3) with latest amendments	Small sized Valve Regulated Lead -Acid Batteries (SMF) conforming to JISC: 8702/1998 (Part 1,2 & 3) with latest amendments , Stationary Lead-Acid Batteries (with tubular positive plates) in Monobloc Container conforming to IS:13369/1992 , Stationary cells and Batteries, Lead Acid Type (With Tubular Positive Plates) conforming to IS:1651/1991 , Stationary Valve

			Regulated Lead Acid Batteries conforming to IS:15549/2005 , Lead-Acid Storage Batteries for Motor Vehicles with Light weight and High Cranking Performance conforming to IS:14257/1995 , Lead-Acid Storage Batteries for Motor Vehicles conforming to IS:7372/1995
	Nominal Voltage of Battery (volts)	12.0 Volt	2.0 Volt , 6.0 Volt , 12.0 Volt
	Material of container	Polypropylene	Hard Rubber , Fibre Reinforced Plastics (FRP) , Polypropylene , ABS
	Rated Capacity at C20 discharge (AH)	42	1-300
	Warranty (Years)	2 Years	1 Year , 2 Years , 3 Years , 4 Years , 5 Years
	Battery Condition	Dry Charged	*
CONSTRUCTIONAL	Dimensions (L x W x H) (mm x mm x mm)	As per relevant IS Specifications	*
	Volume of Electrolyte (ml)	10.9	*
	Weight of Dry Battery (Kg) shall be as per relevant IS: Specn., corresponding Ah	Yes.	*
	No.of cells per Battery (No.)	6 Cells for 12 Volt battery	*
CERTIFICATIONS	Availability of Test Reports from Central Govt./NABL/ILAC accredited Lab showing conformity to the specifications	Yes	*
	Address of the Lab	ETDC, THIRUVANMIYUR, CHENNAI-600041	*
	Name of the Lab	ETDC	*
	Test Report No.	ETDC(CN)2002/965	*
	Test Report Date	11.09.2017	*
	Compulsory Registration (CRS) of	YES	*

	BIS for safety as per IS 16046 as applicable. Secondary Cells and (Batteries containing Alkaline or other non-acid Electrolytes-Safety Requirements for Portable sealed secondary cells, and for Batteries made from them for use in portable applications		
--	--	--	--

* Bold specifications are the golden parameters.

Consignees and Quantity

S.No.	Consignee	Address	Quantity	Delivery Days
1	Paras Mal Kansara	342006,ALL INDIA RADIO, PAOTA C ROAD	28	15

EMD Detail

Required	No
----------	----

ePBG Detail

Required	No
----------	----

Splitting

Bid splitting not applied.

Buyer Specific Additional Terms and Conditions

- 1. Scope of supply (Bid price to include all cost components) :** Only supply of Goods
- 2. Procurement under this bid is reserved for purchase from :** Local Supplier as defined in Public Procurement (Preference to Make in India), Order 2017 and its subsequent Orders / Notifications issued by concerned Nodal Ministry for specific Goods/ Products.
- 3. Purchase preference will be given to MSME and Startup (Local supplier) : (if L-1 is not from selected category and 4 / 5 Seller (s) from selected category has/have quoted price within L-1 + Local Supplier as defined in Public Procurement (Preference to Make in India - 20%), Order 2017 and its subsequent Orders / Notifications issued by concerned Nodal Ministry for specific Goods/ Products % of margin of purchase preference /price band defined in relevant policy, such Seller shall be given opportunity to match L-1 price and award contract for percentage of total value as defined/ decided in relevant policy)** Local Supplier as defined in Public Procurement (Preference to Make in India - 20%), Order 2017 and its subsequent Orders / Notifications issued by concerned Nodal Ministry for specific Goods/ Products
- 4. Inspection charges shall be borne by the supplier and it shall not be reimbursed by indenter to them at any point in time. Cost of inspection shall be factored in by the supplier in the cost of the product itself while submitting bid. The inspection**

agency will conduct the inspection and submit the certificate to the supplier as well as the buyers and consignees. The bidder will be solely responsible for pre-inspected material for Quality Assurance including pre-despatch inspection/ testing at manufacturer's site by IIT

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---